



ITEM	QUAN.	FIGURE	DESCRIPTION
A	4	-	U-BOLT WITH HDWR (SEE NOTES)
B	1	-	3" X 3" X 1/4" ANGLE
C	1	-	BE & K RUBBER LINED SUPPORT
D	1	-	3" X 3" X 1/4" ANGLE
E	2	-	C6 X 10.5 CHANNEL
F	4	-	1/4" X 3" X 9" PLATE
G	8	-	3/4" DIA. ANCHORS
H	2	-	3/4" X 6" X 12" PLATE
I	2	-	BE & K GUIDE TYPE (3)
J	1	-	3" X 3" X 1/4" ANGLE
K	6	-	1" X 1" X 1/4" ANGLE
L	1	-	3" X 3" X 1/4" ANGLE
M	3	-	1-1/2" X 1-1/2" X 1/4" ANGLE

NOTES:

1. Finish for carbon steel threaded components is Zinc Plated. Finish for carbon steel fabricated components to be Hot Dip Galvanized unless noted otherwise.
 2. Stainless Steel components will have no finish
 3. All welds to be 1/4" fillet unless noted otherwise.
 4. U-bolts are to have rubberlined shields top and bottom (attach with ss banding)
- Additional Pipe Loads: xxxx Lat. xxxx Axial

0	05-21-09	Issued for Approval
Rev.	Date	Description
PIPE SPECIFICATIONS		Fenny Engineering Co. Venice, Florida LOWER COLORADO RIVER AUTHORITY FAYETTE POWER UNITS 1 & 2 SCRUBBER LaGrange, Texas ENGINEERS: BURNS & McDONNELL CONTRACTOR: BE&K CONSTRUCTION COMPANY, INC. APS JOB NO: 744 PO#: 6030236-40136
PIPE SIZE: MULTI		
TEMPERATURE:		
INSULATION: None		
MATERIAL: A-36 HDG		
PIPE SYSTEM:		
LOAD (dn):		

REFERENCE DRAWINGS		REVISION NO.
1) _____	3) _____	0
2) _____	4) _____	
		SH. 1 OF 1

QUANTITY	MARK NUMBER
1	C-SD-431-PSM6